



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

TEL. NO. (230) 404 2000
TELEFAX NO. (230) 454 7630 / 7632
E-MAIL: ceb@intnet.mu
WEBSITE: ceb.intnet.mu
VAT Reg. No. VAT22000591
BRN: F07000041

CORPORATE OFFICE
P.O Box 134 | Rue du Savoir | Cyber City, Ebène
MAURITIUS

OUR REF:

YOUR REF:

OAB-TD-4170 - Cla 1

05 February 2018

Attention: All Bidders

Dear Sir/Madam,

OAB-TD-4170- Procurement of Low Voltage Underground Cables

Clarification No 1

Please find below CEB's reply to a query from a bidder in respect of the abovementioned bidding exercise.

Query 1

Please refer to ITB 12.1 (h).

- 2 Type Test Report from an independent approved testing Laboratory/Agency in respect of transformer type (core or shell) proposed.
- 3 Test report for Special test- short circuit test- as per IEC 60076-5 from an independent approved testing Laboratory/Agency. The test shall have been carried during the last three years

These requirements shall not apply to Power Cable. Please clarify?

Reply 1

Please note that the content of ITB 12.1 (h) in the Bidding Data sheet of the above Bidding Document is deleted and replaced as follows:

Bidders must submit the following documents to establish the Conformity of the Goods.

1. Company Profile with Financial Statements for the last three years
2. Pamphlets/Catalogues/Drawings
3. The Guaranteed particular sheets attached to the bid form, and other requirements as mentioned in Specifications under Section V- Schedule of Requirements
4. Type Test Report from an independent approved testing Laboratory/Agency in respect of the item proposed complying with IEC 60502-2 standard

Kindly acknowledge receipt of this letter addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by 07 February 2018.

Yours faithfully,



 R. Chowdharry
Supply Chain Manager