



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

# Central Electricity Board

TEL. NO. (230) 404 2000  
TELEFAX NO. (230) 454 7630 / 7632  
E-MAIL: [ceb@intnet.mu](mailto:ceb@intnet.mu)  
WEBSITE: [ceb.intnet.mu](http://ceb.intnet.mu)  
VAT Reg. No. VAT22000591  
BRN: F07000041

CORPORATE OFFICE  
P.O Box 134 | Rue du Savoir | Cyber City, Ebène  
MAURITIUS

OUR REF:

YOUR REF:

OAB-TD-4171 - Cla 1

26 January 2018

**Attention: All Bidders**

Dear Sir/Madam,

## OAB-TD-4171- Procurement of Power Cable

### Clarification No 1

Please find below CEB's reply to a query from a bidder in respect of the abovementioned bidding exercise.

#### Query 1

Please refer to ITB 12.1 (h).

- 2 Type Test Report from an independent approved testing Laboratory/ Agency in respect of transformer type (core or shell) proposed.
- 3 Test report for Special test- short circuit test- as per IEC 60076-5 from an independent approved testing Laboratory/ Agency. The test shall have been carried during the last three years

These requirements shall not apply to Power Cable. Please clarify?

#### Reply 1

Please note that the content of ITB 12.1 (h) in the Bidding Data sheet of the above Bidding Document is deleted and replaced as follows:

Bidders must submit the following documents to establish the Conformity of the Goods.

1. Company Profile with Financial Statements for the last three years
2. Pamphlets/Catalogues/Drawings
3. The Guaranteed particular sheets attached to the bid form, and other requirements as mentioned in Specifications under Section V- Schedule of Requirements
4. Type Test Report from an independent approved testing Laboratory/ Agency in respect of the item proposed complying with IEC 60502-2 standard

Kindly acknowledge receipt of this letter addressed to the Chairman Tender Committee at [ctc@ceb.intnet.mu](mailto:ctc@ceb.intnet.mu) at latest by 29 January 2018.

Yours faithfully,



**J. Moorghen**  
**Officer in Charge**  
**(Supply Chain Dept)**