



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

# Central Electricity Board

CORPORATE OFFICE

P.O Box 134 | Rue du Savoir | Cyber City, Ebène  
MAURITIUS

TEL. NO. (230) 404 2000  
TELEFAX NO. (230) 454 7630 / 7632  
E-MAIL: ceb@intnet.mu  
WEBSITE: ceb.intnet.mu  
VAT Reg. No. VAT22000591  
BRN: F0700041

OUR REF: **OAB-TD-4171-Cla 3**

**22 February 2018**

YOUR REF:

## **Attention: All Bidders**

Dear Sir/Madam,

## **OAB-TD-4171 - Procurement of Power Cable**

### **Clarification No.3**

Please find below CEB's replies to queries from bidders in respect of the abovementioned bidding exercise.

#### **Query 1**

Please indicate the copper tape screen area in mm<sup>2</sup> for each core or the short circuit current of screen for each core KA/S (System neutral grounding mode).

#### **Reply 1**

Please note that the short circuit current of screen for each core KA/S is 16KA/1 s.  
The System neutral grounding mode shall be effectively earthed.

#### **Query 2**

As per ITB 15.7 Clause No.(b) on Page 37 the LME publishing date is mentioned as **07.02.2018**. However, as per the Compulsory Submission Form for Price Variation Formula the LME date is mentioned as **07.01.2018**. Please confirm the date.

#### **Reply 2**

Please note that the LME publishing date is **07.02.2018**. Please find attached revised Compulsory Submission Form for Price Variation Formula.

Please acknowledge receipt by a written confirmation addressed to the Chairman Tender Committee at [ctc@ceb.intnet.mu](mailto:ctc@ceb.intnet.mu) by **23 February 2018** at latest.

Yours faithfully,

A handwritten signature in blue ink, appearing to read "R. Chowdhary", enclosed within a large, loopy blue circular scribble.

**R. Chowdhary**  
**Supply Chain Manager**