



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

TEL. NO. (230) 404 2000
TELEFAX NO. (230) 454 7630 / 7632
E-MAIL: ceb@intnet.mu
WEBSITE: ceb.intnet.mu
VAT Reg. No. VAT22000591
BRN: F07000041

CORPORATE OFFICE
P.O Box 134 | Rue du Savoir | Cyber City, Ebène
MAURITIUS

OAB-TD-4180 - Cla 2

26 March 2018

OUR REF:

YOUR REF:

Attention: All Bidders

Dear Sir/Madam,

OAB-TD-4180- Procurement of Medium Voltage Insulated Twisted Cable

Clarification No 2

Please find below CEB's reply to queries from prospective bidders in respect of the abovementioned bidding exercise.

Query 1

What is the preferred thickness in mm of copper tape? If the copper tape thickness is not known can you advise what is the KA/S requirement is for short-circuit current of the copper tape earth screened? This data is very important, it will affect cable cost much.

Reply 1

Please note that The KA/S requirement of the tape is 0.2 KA for 1 Sec.

Query 2

The cable will be with copper tape earth screened, so, the copper cost is also one of the main cost for the cable and not only the Aluminium. So, the Price Variation Formula should also add the copper cost variation, please confirm.

Reply 2

In view of the negligible size of the copper tape with respect to the actual size of the main conductor, the cost for copper is not accounted for in the price variation formula.

Query 3

Type Test Reports shall be from an independent recognised testing laboratory, according to IEC 60502-2, and shall include tests on the strain bearing messenger.

Kindly confirm whether the type test report needed should be exactly same size (35 mm, 95 mm, 150 mm) as per the cables requirements in the tender.

Reply 3

Please note that the Type Test Report shall be of same size of conductor or bigger.

Kindly acknowledge receipt of this letter addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by **28 March 2018**.

Yours faithfully,

A handwritten signature in blue ink, appearing to read 'R. Chowdharry', is written over a circular stamp or seal.

R. Chowdharry
Supply Chain Manager