



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

CORPORATE OFFICE

P.O Box 134 | Rue du Savoir | Cyber City, Ebène 72201
MAURITIUS

TEL NO. : (230) 404 2000
FAX NO. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.intnet.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

OUR REF : **OAB-TD-4181 - Cla 1**

22 March 2018

YOUR REF:

Attention: All Bidders

Dear Sir/Madam,

OAB-TD-4181- Procurement of Meter Box

Clarification No 1

Please find below CEB's reply to a query from a prospective bidder in respect of the abovementioned bidding exercise.

Query 1

Is it acceptable that the Meter Box is made from Polycarbonate + Fiber Glass?

Reply 1

Please note that the Meter Box shall be made from Polyester Moulding Compound comprising of fibreglass material. Bidders are kindly requested to stick to this requirement.

Kindly acknowledge receipt of this letter addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by 23 March 2018.

Yours faithfully,

R. Chowdharry
Supply Chain Manager