



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

CORPORATE OFFICE

P.O.BOX 134 | Rue du Savoir | Cyber City, Ebène 72201
MAURITIUS

TEL No. : (230) 404 2000
TELEFAX No. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.intnet.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

OUR REF:

YOUR REF: **OAB-TD-4206 - Cla 1**

08 June 2018

Attention: All Bidders

Dear Sir/Madam,

OAB-TD-4206 - Procurement of Copper Cables 66kV - 1 x 630mm²

Clarification No 1

Please find below CEB's reply to queries from a prospective bidder in respect of the abovementioned bidding exercise.

Query 1

Cable Marking:

Tender document didn't specify certain cable marking, please advise required cable marking, or approve using our below proposed cable marking:

***" Name of Manufacturer CABLES 1X630 mm² 38/66 kV Cu/XLPE/CWS/HDPE
CEB Manufacturing Year "***

Embossed - Two lines along the axis of the cables, approximately equally spaced around the circumference of the cable.

Reply 1

The following information must be clearly marked on cable outer sheath at intervals of 1 metre:

- a) Name of Manufacturer
- b) Year of Manufacture
- c) Size of cable: "1x630mm²"
- d) Cable Construction details: "Cu/XLPE/CWS/HDPE"
- e) Metre position of this mark
- f) The words "CEB 66 kV Cable "

Query 2

Drum Length:

As per tender documents, nominal drum length should be 300 meters, is there maximum length allowed per drum?

Reply 2

The maximum continuous length of cable allowed per drum is 330m (300m + 10%).

Kindly acknowledge receipt of this letter addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by **12 June 2018**.

Yours faithfully,



R. Chowdhary
Supply Chain Manager