



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

TEL. NO. (230) 404 2000
TELEFAX NO. (230) 454 7630 / 7632
E-MAIL: ceb@intnet.mu
WEBSITE: ceb.intnet.mu
VAT Reg. No. VAT22000591
BRN: F07000041

CORPORATE OFFICE
P.O Box 134 | Rue du Savoir | Cyber City, Ebène
MAURITIUS

OUR REF: OAB-FIN-4014-Cla 2

YOUR REF:

18 April 2016

Attention: All Bidders

Dear Sir/Madam,

OAB-FIN-4014- Provision of Fire Insurance/All Risks Insurance Cover

Clarification No 2

Please find below CEB's reply to the following queries from bidders in respect of the abovementioned bidding exercise.

Query 1

We have noted that the following substations are missing in the Schedule of Insured Values.

1. New Major Substation at La Tour Koenig - Rs 158,856,578
2. Majenta - Rs 45,000,000.

Reply 1

Please note that the Total Sum insured should be increased by Rs 158,856,578 to cater for a new Substation recently commissioned. As regards the Majenta Hydro Station, the CEB do not intend to insure.

Query 2

Kindly advise on reports pertaining to loss control measures for the main locations detailing major plant and machinery, plant layout.

Reply 2

Please note that appropriate loss control measures, as per best practice, are in place and we are also required to have a Fire Certificate as per local Legislation in order to be operational.

Query 3

Please provide Make and Models of all the Gensets, turbines, substations and other related electrical information

Reply 3

We are pleased to provide the underneath information that are as per Risk Survey Exposure Report 2013:

Location	Details of Units	Service Date
Fort George Power Station	2 x Sulzer 24MW two stroke slow speed HFO fired diesel generators	1992 & 1993 respectively
	1 x Mitsui Man B&W 30MW two stroke slow speed HFO fired diesel generators	1997
	2 x HHI MAN B&W 30MW two stroke slow speed HFO fired diesel generators	1999 & 2000 respectively
St Louis Power Station	4 x Pielstick 6MW medium speed HFO fired diesel generators	Between 1978 and 1979
	3 x Wartsila 13.8MW diesel generators	2006
Nicolay Gas Turbine	2 x EGT Frame 5, 22MW open cycle gas turbines firing JET1 fuel	Between 1988 and 1991
	1 x EGT Frame 6, 32MW open cycle gas turbines firing JET1 fuel	1995
Fort Victoria Power Station	6 x Wartsila 16V46, 15MW medium speed HFO fired diesel generators	Between 2010 and 2012
	2 x MAN B&W 9.8MW medium speed HFO fired diesel generators	1989
Port Mathurin Power Station	6 x Deutz MWM 0.5MW LFO fired sets	Between 1985 and 1993
	3 x MAN B&W 1MW medium speed HFO fired diesel generators	Between 1995 and 1998

Pointe Monnier Power Station	2 x MAN 1.9 MW HFO fired diesel generators	2004
	1 x Wartsila 6L32, 4 stroke medium speed diesel 3,295 KVA generator	2012
Ferney Hydro Power Station	2 x Bell Engineering Francis Type Turbines – 5MW	1971
Champagne Hydro Power Station	2 x Ansaldo Francis Type Turbines 15MW	1984
Tamarin Falls Hydro Station	1 x Neypric Pelton Turbine 4MW	1987
	2 x Gilkes Turgo Turbines 2MW	Between 1945 and 1946
	1 x Gilkes Turgo Turbines 3MW	1953
Le Val Hydro Station	2 x Gilkes Turgo Turbines 2MW	1961
Reduit Hydro Station	1 x Dumont Francis Turbine 1.2MW	1984
Cascade Cecile Hydro Station	1 x Gilkes Francis Turbine 1MW	1963
La Ferme Hydro Station	1 x Gilkes Francis Turbine 1.2MW	1988
La Nicoliere Hydro Station	1 x micro hydro fed 0.35MW	2010
Midlands Dam Hydro Station	1 x micro hydro-electric plant 0.35MW	2012

Query 4

Please provide detailed loss history showing ground of losses for at least a 5 year period

Reply 4

Kindly find below the detailed loss history.

Loss History				
Year	Particulars	Claim Lodged (MUR)	Excess Limit (MUR)	Compensation Received (MUR)
2011	Fire at St Louis P/Stn	14,249,400	7,500,000	6,749,400
2012	No Claim			
2013	No Claim			
2014	No Claim			
2015	No Claim			
2016 (Jan to April)	Majenta Hydro Station - Bursting of Pipe	45,000,000	10,000,000	Still Outstanding

Query 5

Please provide detailed schedule of values.

Reply 5

Please note that these information will be provided to the successful Bidder.

Kindly acknowledge receipt of this letter through our fax number (230) 454-7630/32 or addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by 20 April 2016.

Yours faithfully,

A handwritten signature in blue ink, appearing to read 'R. Chowdharry', written in a cursive style.

R. Chowdharry
Officer-in-Charge
(Supply Chain Department)