



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

TEL. NO. : (230) 404 2000
TELEFAX NO. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.intnet.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

CORPORATE OFFICE
P.O Box 134 | Rue du Savoir | Cyber City, Ebène 72201
MAURITIUS

OUR REF:

OAB-CS-4106- Add 2

YOUR REF:

27 September 2017

Attention: All Bidders

Dear Sir/Madam,

OAB-CS-4106-Construction of New Customer Service Building and Upgrading Works to existing office at CEB Goodlands

Addendum No 2

We refer to the abovementioned bidding exercise and are pleased to inform bidders as follows.

1. Item C.3.1 to the Domestic water pump specifications

- (i) Regarding the paragraph "controls", kindly read the paragraph as follows:

The controller shall operate the pump after detecting a fall in pressure in the pipeline via a pressure transducer. Each pump hydraulic capacity must be designed to meet the total capacity requirements of the system. However, the pressure transducer settings shall allow that in the event 1 pump cannot restore the pressure level, the 2ND pump shall start.

Moreover, the controller must imperatively ensure that the starting order of the pumps is monitored by a frequency controller, which is the pump that has been running the most is the last to start again. This control strategy is to ensure even wear of the pumps. Finally, the pump set's control must be fitted with a Duty/Standby control to ensure automatic starting of 2ND pump in the event the 1ST pump fails (pump start failure).


2. Bill Item D.3 (vi) D/2, kindly read the "pressure vessel capacity" as 100L.

3. Item C.8 to the Fire-fighting pump Specifications

- (i) The paragraph "duty" of the fire-fighting pump set, shall read the duty as 5m³/hr@50m.
- (ii) The paragraph "controls" of the fire-fighting pump set, bidders are requested to disregard the term "variable speed"

Kindly acknowledge receipt of this letter by e-mail addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest 29 September 2017.

Yours faithfully,

A handwritten signature in blue ink, appearing to be 'J. Moorghen', written over a faint circular stamp.

J. Moorghen
Officer-in-Charge
Supply Chain Department