



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

TEL. NO. : (230) 404 2000
TELEFAX NO. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.intnet.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

CORPORATE OFFICE
P.O. Box 134 | Rue du Savoir | Cyber City, Ebène 72201
MAURITIUS

OUR REF: **OAB-CS-4106 - Cla 2**

28 August 2017

YOUR REF:

Attention: All Bidders

Dear Sir/Madam,

OAB-CS-4106-Construction of New Customer Service Building and Upgrading Works to existing office at CEB Goodlands

Clarification No 2

Please find below CEB's reply to the queries from bidders in respect of the abovementioned bidding exercise.

Query 1

With regards to the BOQ, I would like to have some clarification on the below item: Bill 8, Item 8.37 - Temporary fillet. May I know which temporary fillet are you talking about? I couldn't find it in Detail A.

Reply 1

Please note that the temporary fillet refers to formwork required for forming the 20 x 30 mm groove on both sides of the coping.

Kindly refer to extract of Drawing No RA/16/CEBG/A551R1 and Detail A as annexed.

Query 2

We refer to above-named tender and would be grateful if you could send us Bill of Quantities in order to enable us to do our pricing.

Reply 2

Please note that Bill of Quantities in Excel format is not available.

Query 3

In Bill No 4 - Renovation Works to Existing Office Building, Page 4C/4, Item No C.9, there is mentioned of door (F1) but no detail is provided on the Drawing No RA/16/CEBG/A502 for this specific door. Please clarify.

Reply 3

Detail for door (F1) is provided in Schedule of Openings 2. Please refer to Drawing No. RA/16/CEBG/A501 and NOT Drawing No RA/16/CEBG/A502. There is a typing mistake in the BOQ.

Query 4

Please note that there is discrepancy in the Architect's Drawing Register and the Architect's drawings. The drawing number in the drawing register does not tally with those in the Architect's drawing. Can you please issue a revised drawing register which reflects the actual tender drawings issued.

Reply 4

Please refer to the amended list of drawings. Bidders are requested to collect the revised drawings in CD format at the Central Electricity Board at Curepipe during working hours.

Kindly acknowledge receipt of this letter by mail addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by **30 August 2017**.

Yours faithfully,



J. Moorghen
Officer-in-Charge
Supply Chain Department

