



ALL CORRESPONDENCE TO BE ADDRESSED TO THE GENERAL MANAGER

Central Electricity Board

TEL. NO. : (230) 404 2000
TELEFAX NO. : (230) 454 7630 / 7632
E-MAIL : ceb@intnet.mu
WEBSITE : ceb.intnet.mu
VAT Reg. No. : VAT22000591
BRN : F07000041

CORPORATE OFFICE
P.O Box 134 | Rue du Savoir | Cyber City, Ebène 72201
MAURITIUS

OUR REF

OAB-CS-4106 - Cla 5

27 September 2017

YOUR REF

Attention: All Bidders

Dear Sir/Madam,

OAB-CS-4106-Construction of New Customer Service Building and Upgrading Works to existing office at CEB Goodlands

Clarification No 5

Please find below CEB's reply to the query from a bidder in respect of the abovementioned bidding exercise.

Query 1

We would like to get a clarification concerning Bill item E.1 (ii) Page 9E/1 which mentioned that it is made for sound pressure level 55dB (A)@1m in full load operation or 65dB(A)@5m?

Reply 1

Kindly read the sound pressure level as 75dB (A)@1m or 65dB (A)@7m.

Kindly acknowledge receipt of this letter by e-mail addressed to the Chairman Tender Committee at ctc@ceb.intnet.mu at latest by **29 September 2017**.

Yours faithfully,

J. Moorghen
Officer-in-Charge
Supply Chain Department